



## Service Report

100 GPD R.O System, 05 Units

Customer Name: Wise Indian Private School

Service Date: 27-08-2024

Address: Umm Al Quwain

Serviced By: M. Hassan

### Unit # 1 (Ground Floor, near Computer Lab.)

| 03 Consumable Cartridges | R.O Membrane | Sterilizer Filter | Booster Pump | Post Carbon Filter | Post Mineral Filter | T.D.S mg/ltr. | Ph. Value |
|--------------------------|--------------|-------------------|--------------|--------------------|---------------------|---------------|-----------|
| Replaced                 | ✓            | ✓                 | ✓            | ✓                  | ✓                   | 61            | 7.7       |

| Unit Physical Condition | Water Quality Physically | Water Quality Microbiologically | Water Quality Chemically | Water Cooler Tank Cleaning | Remarks                |
|-------------------------|--------------------------|---------------------------------|--------------------------|----------------------------|------------------------|
| Good                    | Satisfactory             | Satisfactory                    | Not Available            | Cleaned                    | Good working condition |

### Unit # 2 (Ground Floor, near School Clinic)

| 03 Consumable Cartridges | R.O Membrane | Sterilizer Filter | Booster Pump | Post Carbon Filter | Post Mineral Filter | T.D.S mg/ltr. | Ph. Value |
|--------------------------|--------------|-------------------|--------------|--------------------|---------------------|---------------|-----------|
| Replaced                 | ✓            | ✓                 | ✓            | ✓                  | ✓                   | 58            | 7.8       |

| Unit Physical Condition | Water Quality Physically | Water Quality Microbiologically | Water Quality Chemically | Remarks                |
|-------------------------|--------------------------|---------------------------------|--------------------------|------------------------|
| Good                    | Satisfactory             | Satisfactory                    | Not Available            | Good working condition |

### Unit # 3 (First Floor, near Prayer Room)

| 03 Consumable Cartridges | R.O Membrane | Sterilizer Filter | Booster Pump | Post Carbon Filter | Post Mineral Filter | T.D.S mg/ltr. | Ph. Value |
|--------------------------|--------------|-------------------|--------------|--------------------|---------------------|---------------|-----------|
| Replaced                 | ✓            | ✓                 | ✓            | ✓                  | ✓                   | 63            | 7.6       |

| Unit Physical Condition | Water Quality Physically | Water Quality Microbiologically | Water Quality Chemically | Remarks                |
|-------------------------|--------------------------|---------------------------------|--------------------------|------------------------|
| Good                    | Satisfactory             | Satisfactory                    | Not Available            | Good working condition |

### Unit # 4 (First Floor, near Cyber Squire)

| 03 Consumable Cartridges | R.O Membrane | Sterilizer Filter | Booster Pump | Post Carbon Filter | Post Mineral Filter | T.D.S mg/ltr. | Ph. Value |
|--------------------------|--------------|-------------------|--------------|--------------------|---------------------|---------------|-----------|
| Replaced                 | Replaced     | ✓                 | ✓            | Replaced           | Replaced            | 48            | 7.8       |

| Unit Physical Condition | Water Quality Physically | Water Quality Microbiologically | Water Quality Chemically | Remarks                |
|-------------------------|--------------------------|---------------------------------|--------------------------|------------------------|
| Good                    | Satisfactory             | Satisfactory                    | Not Available            | Good working condition |

### Unit # 5 (Ground Floor, K.G Section)

| 03 Consumable Cartridges | R.O Membrane | Sterilizer Filter | Booster Pump | Post Carbon Filter | Post Mineral Filter | T.D.S mg/ltr. | Ph. Value |
|--------------------------|--------------|-------------------|--------------|--------------------|---------------------|---------------|-----------|
| Replaced                 | Replaced     | ✓                 | ✓            | Replaced           | Replaced            | 44            | 7.9       |

| Unit Physical Condition | Water Quality Physically | Water Quality Microbiologically | Water Quality Chemically | Remarks                |
|-------------------------|--------------------------|---------------------------------|--------------------------|------------------------|
| Good                    | Satisfactory             | Satisfactory                    | Not Available            | Good working condition |